

Subtype HA 3-8.2 OS 230V, HA 5-8.2 OS 230V with Hydraulic station

Certificate Holder	Saunier Duval Brand Group
Address	SDECCI SAS - 17 rue de la Petite Baratte
ZIP	44300
City	Nantes
Country	FR
Certification Body	DIN CERTCO Gesellschaft für Konformitätsbewertung mbH
Subtype title	HA 3-8.2 OS 230V, HA 5-8.2 OS 230V with Hydraulic station
Registration number	011-1W0950
Heat Pump Type	Outdoor Air/Water
Refrigerant	R32
Mass of Refrigerant	1.3 kg
Certification Date	11.12.2024
Testing basis	HP KEYMARK certification scheme rules rev. 14

Model HA 6-8.2 OS 230V B3 + HA 6-8.2 WSB

Model name	HA 6-8.2 OS 230V B3 + HA 6-8.2 WSB
Application	Heating (medium temp)
Units	Indoor, Outdoor
Climate zone (for heating)	Colder, Warmer
Reversibility	Yes
Cooling mode application (optional)	+7°C/12°C, +18°C/+23°C
Any additional heat sources	n/a

General data

Power supply	1x230V 50Hz
Off-peak product	n/a

Outdoor Air/Water**EN 14511-4 | Heating**

Shutting off the heat transfer medium flow passed

Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

EN 14511-2 | Heating

	Low temperature	Medium temperature
Heat output	4.51 kW	5.36 kW
El input	0.92 kW	1.89 kW
COP	4.89	2.83

EN 14511-2 | Cooling

	+7°C/+12°C	+18°C/+23°C
El input	1.73 kW	1.26 kW
Cooling capacity	5.22	5.31
EER	3.03	4.22

EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level indoor	41 dB(A)	41 dB(A)
Sound power level outdoor	48 dB(A)	48 dB(A)

EN 14825 | Average Climate

	Low temperature	Medium temperature
η_s	192 %	129 %
Prated	4.72 kW	4.35 kW
SCOP	4.87	3.30
Tbiv	-7 °C	-7 °C

TOL	-10 °C	-10 °C
Pdh Tj = -7°C	4.18 kW	3.85 kW
COP Tj = -7°C	3.13	2.10
Cdh Tj = -7 °C	1.00	1.00
Pdh Tj = +2°C	2.67 kW	2.13 kW
COP Tj = +2°C	4.84	3.18
Cdh Tj = +2 °C	1.00	1.00
Pdh Tj = +7°C	2.43 kW	2.21 kW
COP Tj = +7°C	6.24	4.39
Cdh Tj = +7 °C	0.97	0.97
Pdh Tj = 12°C	2.84 kW	2.72 kW
COP Tj = 12°C	8.04	6.03
Cdh Tj = +12 °C	0.96	0.97
Pdh Tj = Tbiv	4.18 kW	3.85 kW
COP Tj = Tbiv	3.13	2.10
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	4.06 kW	3.33 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.81	1.66
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	1.00	1.00
WTOL	60 °C	60 °C
Poff	14 W	14 W
PTO	13 W	13 W
PSB	14 W	14 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.66 kW	1.02 kW
Annual energy consumption Qhe	2003 kWh	2727 kWh

EN 12102-1 | Colder Climate

	Low temperature	Medium temperature
Sound power level indoor	41 dB(A)	41 dB(A)
Sound power level outdoor	48 dB(A)	48 dB(A)

EN 14825 | Colder Climate

	Low temperature	Medium temperature
η_s	162 %	111 %
Prated	5.44 kW	3.97 kW
SCOP	4.13	2.86
Tbiv	-15 °C	-15 °C
TOL	-20 °C	-15 °C
Pdh Tj = -7°C	3.46 kW	2.27 kW
COP Tj = -7°C	3.54	2.51
Cdh Tj = -7 °C	1.00	1.00
Pdh Tj = +2°C	2.02 kW	1.86 kW

COP Tj = +2°C	5.02	3.53
Cdh Tj = +2 °C	0.97	0.98
Pdh Tj = +7°C	2.42 kW	2.28 kW
COP Tj = +7°C	6.67	4.84
Cdh Tj = +7 °C	0.96	0.97
Pdh Tj = 12°C	2.83 kW	2.73 kW
COP Tj = 12°C	7.95	6.34
Cdh Tj = +12 °C	0.96	0.97
Pdh Tj = Tbiv	4.43 kW	3.23 kW
COP Tj = Tbiv	2.57	1.84
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	2.99 kW	3.23 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.19	1.84
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	1.00	1.00
WTOL	60 °C	60 °C
Poff	14 W	14 W
PTO	13 W	13 W
PSB	14 W	14 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	5.44 kW	3.97 kW
Annual energy consumption Qhe	3244 kWh	3423 kWh
Pdh Tj = -15°C (if TOL	4.43	3.23
COP Tj = -15°C (if TOL	2.57	1.84
Cdh Tj = -15 °C	1.00	1.00

EN 12102-1 | Warmer Climate

	Low temperature	Medium temperature
Sound power level indoor	41 dB(A)	41 dB(A)
Sound power level outdoor	48 dB(A)	48 dB(A)

EN 14825 | Warmer Climate

	Low temperature	Medium temperature
η_s	252 %	170 %
Prated	5.01 kW	4.68 kW
SCOP	6.37	4.32
Tbiv	2 °C	2 °C
TOL	2 °C	2 °C
Pdh Tj = +2°C	5.01 kW	4.68 kW
COP Tj = +2°C	3.54	2.26
Cdh Tj = +2 °C	1.00	1.00
Pdh Tj = +7°C	3.00 kW	2.95 kW
COP Tj = +7°C	5.84	3.59
Cdh Tj = +7 °C	0.97	0.98

Pdh Tj = 12°C	2.81 kW	2.67 kW
COP Tj = 12°C	7.91	5.92
Cdh Tj = +12 °C	0.96	0.97
Pdh Tj = Tbiv	5.01 kW	4.68 kW
COP Tj = Tbiv	3.54	2.26
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	5.01 kW	4.68 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	3.54	2.26
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	1.00	1.00
WTOL	60 °C	60 °C
Poff	14 W	14 W
PTO	13 W	13 W
PSB	14 W	14 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Qhe	1050 kWh	1447 kWh

EN 14825 | Cooling

	+7°C/+12°C	+18°C/+23°C
Pdesignc	3.88 kW	5.19 kW
SEER	4.69	6.94
Pdc Tj = 35°C	3.88 kW	5.19 kW
EER Tj = 35°C	3.25	4.13
Cdc Tj = 35 °C	1.000	1.000
Pdc Tj = 30°C	2.64 kW	3.81 kW
EER Tj = 30°C	4.01	5.98
Cdc Tj = 30 °C	1.000	1.000
Pdc Tj = 25°C	2.28 kW	3.11 kW
EER Tj = 25°C	5.41	8.34
Cdc Tj = 25 °C	0.969	0.965
Pdc Tj = 20°C	2.50 kW	3.27 kW
EER Tj = 20°C	6.97	10.65
Cdc Tj = 20 °C	0.963	0.957
Poff	14 W	14 W
PTO	13 W	13 W
PSB	14 W	14 W
PCK	0 W	0 W
Annual energy consumption Qce	496 kWh	449 kWh