

This information was generated by the HP KEYMARK database on 28 Sep 2022

[Login](#)

Summary of	VWL 45/7.2 AS 230V S3 / VWL 65/7.2 AS230V S3	Reg. No.	011-1W0553
Certificate Holder			
Name	Vaillant Deutschland GmbH & Co KG		
Address	Berghauser Straße 40	Zip	42859
City	Remscheid	Country	Germany
Certification Body	DIN CERTCO Gesellschaft für Konformitätsbewertung mbH		
Subtype title	VWL 45/7.2 AS 230V S3 / VWL 65/7.2 AS230V S3		
Heat Pump Type	Outdoor Air/Water		
Refrigerant	R32		
Mass of Refrigerant	1 kg		
Certification Date	26.09.2022		
Testing basis	European KEYMARK Scheme for Heat Pumps Rev. 10 (as of 2022-06)		

# Model: VWL 45/7.2 AS 230V S3 + VWL 107/7.2 IS

Configure model	
Model name	VWL 45/7.2 AS 230V S3 + VWL 107/7.2 IS
Application	Heating (medium temp)
Units	Indoor + Outdoor
Climate Zone	Colder Climate + Warmer Climate
Reversibility	Yes
Cooling mode application (optional)	+7°C/12°C and +18°C/+23°C

General Data	
Power supply	1x230V 50Hz

## Heating

EN 14511-2		
	Low temperature	Medium temperature
Heat output	4.21 kW	4.32 kW
El input	0.79 kW	1.48 kW
COP	5.31	2.91

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

## Cooling

This information was generated by the HP KEYMARK database on 28 Sep 2022

### EN 14511-2

	+7°C/+12°C	+18°C/+23°C
El input	1.21 kW	0.81 kW
Cooling capacity	3.61	4.00
EER	2.97	4.96

### EN 14825

This information was generated by the HP KEYMARK database on 28 Sep 2022

	<b>+7°C/+12°C</b>	<b>+18°C/+23°C</b>
P <sub>designc</sub>	3.61 kW	3.84 kW
SEER	4.85	7.34
P <sub>dc</sub> T <sub>j</sub> = 35°C	3.61 kW	3.84 kW
EER T <sub>j</sub> = 35°C	2.97	5.07
C <sub>dc</sub> T <sub>j</sub> = 35 °C	1.000	1.000
P <sub>dc</sub> T <sub>j</sub> = 30°C	2.45 kW	3.18 kW
EER T <sub>j</sub> = 30°C	4.08	6.80
C <sub>dc</sub> T <sub>j</sub> = 30 °C	1.000	0.970
P <sub>dc</sub> T <sub>j</sub> = 25°C	2.48 kW	3.45 kW
EER T <sub>j</sub> = 25°C	5.66	8.94
C <sub>dc</sub> T <sub>j</sub> = 25 °C	0.967	0.963
P <sub>dc</sub> T <sub>j</sub> = 20°C	2.85 kW	3.63 kW
EER T <sub>j</sub> = 20°C	8.15	11.65
C <sub>dc</sub> T <sub>j</sub> = 20 °C	0.959	0.954
P <sub>off</sub>	12 W	12 W
P <sub>TO</sub>	6 W	6 W
P <sub>SB</sub>	12 W	12 W
P <sub>CK</sub>	0 W	0 W
Annual energy consumption Q <sub>ce</sub>	446 kWh	314 kWh

## Warmer Climate

### EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	41 dB(A)	41 dB(A)
Sound power level outdoor	63 dB(A)	63 dB(A)

### EN 14825

	Low temperature	Medium temperature
$\eta_s$	225 %	156 %
Prated	4.42 kW	4.27 kW
SCOP	5.71	3.97
Tbiv	2 °C	2 °C
TOL	2 °C	2 °C
Pdh Tj = +2°C	4.42 kW	4.27 kW
COP Tj = +2°C	3.49	2.17
Cdh Tj = +2 °C	1.00	1.00
Pdh Tj = +7°C	2.57 kW	2.75 kW
COP Tj = +7°C	5.53	3.54
Cdh Tj = +7 °C	1.00	0.99
Pdh Tj = 12°C	2.76 kW	2.61 kW
COP Tj = 12°C	6.45	4.89
Cdh Tj = +12 °C	0.99	0.99

This information was generated by the HP KEYMARK database on 28 Sep 2022

Pdh Tj = Tbiv	4.42 kW	4.27 kW
COP Tj = Tbiv	3.49	2.17
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	4.42 kW	4.27 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	3.49	2.17
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	1.00	1.00
WTOL	60 °C	60 °C
Poff	12 W	12 W
PTO	6 W	6 W
PSB	12 W	12 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Qhe	1033 kWh	1438 kWh

## Colder Climate

<b>EN 12102-1</b>		
	<b>Low temperature</b>	<b>Medium temperature</b>
Sound power level indoor	41 dB(A)	41 dB(A)
Sound power level outdoor	63 dB(A)	63 dB(A)

<b>EN 14825</b>
-----------------

This information was generated by the HP KEYMARK database on 28 Sep 2022

	<b>Low temperature</b>	<b>Medium temperature</b>
$\eta_s$	145 %	102 %
Prated	4.12 kW	3.68 kW
SCOP	3.71	2.63
Tbiv	-15 °C	-15 °C
TOL	-20 °C	-15 °C
Pdh Tj = -7°C	2.58 kW	2.26 kW
COP Tj = -7°C	2.88	1.97
Cdh Tj = -7 °C	0.99	1.00
Pdh Tj = +2°C	2.20 kW	2.09 kW
COP Tj = +2°C	4.80	3.58
Cdh Tj = +2 °C	0.99	0.99
Pdh Tj = +7°C	2.74 kW	2.72 kW
COP Tj = +7°C	6.40	4.79
Cdh Tj = +7 °C	0.99	0.99
Pdh Tj = 12°C	2.80 kW	2.69 kW
COP Tj = 12°C	6.64	5.61
Cdh Tj = +12 °C	0.99	0.99
Pdh Tj = Tbiv	3.36 kW	3.00 kW
COP Tj = Tbiv	2.20	1.58
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	2.72 kW	3.00 kW

This information was generated by the HP KEYMARK database on 28 Sep 2022

COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	1.74	1.58
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	1.00	1.00
WTOL	60 °C	60 °C
Poff	12 W	12 W
PTO	6 W	6 W
PSB	12 W	12 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	4.12 kW	3.68 kW
Annual energy consumption Qhe	2742 kWh	3440 kWh
Pdh Tj = -15°C (if TOL<-20°C)	3.36	3.00
COP Tj = -15°C (if TOL<-20°C)	2.20	1.58
Cdh Tj = -15 °C	1.00	1.00

## Average Climate

<b>EN 12102-1</b>		
	<b>Low temperature</b>	<b>Medium temperature</b>
Sound power level indoor	41 dB(A)	41 dB(A)
Sound power level outdoor	63 dB(A)	63 dB(A)

<b>EN 14825</b>
-----------------



This information was generated by the HP KEYMARK database on 28 Sep 2022

	<b>Low temperature</b>	<b>Medium temperature</b>
$\eta_s$	182 %	133 %
Prated	4.75 kW	5.09 kW
SCOP	4.62	3.41
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	4.20 kW	4.50 kW
COP Tj = -7°C	3.08	2.19
Cdh Tj = -7 °C	1.00	1.00
Pdh Tj = +2°C	2.66 kW	2.76 kW
COP Tj = +2°C	4.51	3.35
Cdh Tj = +2 °C	0.99	0.99
Pdh Tj = +7°C	2.72 kW	2.46 kW
COP Tj = +7°C	6.19	4.45
Cdh Tj = +7 °C	0.99	0.99
Pdh Tj = 12°C	3.01 kW	2.65 kW
COP Tj = 12°C	6.46	5.38
Cdh Tj = +12 °C	0.99	0.99
Pdh Tj = Tbiv	4.20 kW	4.50 kW
COP Tj = Tbiv	3.08	2.19
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	3.67 kW	3.37 kW

This information was generated by the HP KEYMARK database on 28 Sep 2022

COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.54	1.60
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	1.00	1.00
WTOL	60 °C	60 °C
Poff	12 W	12 W
PTO	6 W	6 W
PSB	12 W	12 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	1.08 kW	1.71 kW
Annual energy consumption Qhe	2126 kWh	3084 kWh

# Model: VWL 45/7.2 AS 230V S3 + VWL 107/7.2 IS S1

Configure model	
Model name	VWL 45/7.2 AS 230V S3 + VWL 107/7.2 IS S1
Application	Heating (medium temp)
Units	Indoor + Outdoor
Climate Zone	Warmer Climate
Reversibility	Yes
Cooling mode application (optional)	+7°C/12°C and +18°C/+23°C

General Data	
Power supply	1x230V 50Hz

## Heating

EN 14511-2		
	Low temperature	Medium temperature
Heat output	4.21 kW	4.32 kW
El input	0.79 kW	1.48 kW
COP	5.31	2.91

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

## Cooling

This information was generated by the HP KEYMARK database on 28 Sep 2022

### EN 14511-2

	+7°C/+12°C	+18°C/+23°C
El input	1.21 kW	0.81 kW
Cooling capacity	3.61	4.00
EER	2.97	4.96

### EN 14825

This information was generated by the HP KEYMARK database on 28 Sep 2022

	<b>+7°C/+12°C</b>	<b>+18°C/+23°C</b>
P <sub>designc</sub>	3.61 kW	3.84 kW
SEER	4.85	7.34
P <sub>dc</sub> T <sub>j</sub> = 35°C	3.61 kW	3.84 kW
EER T <sub>j</sub> = 35°C	2.97	5.07
C <sub>dc</sub> T <sub>j</sub> = 35 °C	1.000	1.000
P <sub>dc</sub> T <sub>j</sub> = 30°C	2.45 kW	3.18 kW
EER T <sub>j</sub> = 30°C	4.08	6.80
C <sub>dc</sub> T <sub>j</sub> = 30 °C	1.000	0.970
P <sub>dc</sub> T <sub>j</sub> = 25°C	2.48 kW	3.45 kW
EER T <sub>j</sub> = 25°C	5.66	8.94
C <sub>dc</sub> T <sub>j</sub> = 25 °C	0.967	0.963
P <sub>dc</sub> T <sub>j</sub> = 20°C	2.85 kW	3.63 kW
EER T <sub>j</sub> = 20°C	8.15	11.65
C <sub>dc</sub> T <sub>j</sub> = 20 °C	0.959	0.954
P <sub>off</sub>	12 W	12 W
P <sub>TO</sub>	6 W	6 W
P <sub>SB</sub>	12 W	12 W
P <sub>CK</sub>	0 W	0 W
Annual energy consumption Q <sub>ce</sub>	446 kWh	314 kWh

## Warmer Climate

### EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	38 dB(A)	38 dB(A)
Sound power level outdoor	63 dB(A)	63 dB(A)

### EN 14825

	Low temperature	Medium temperature
$\eta_s$	225 %	156 %
Prated	4.42 kW	4.39 kW
SCOP	5.71	3.97
Tbiv	2 °C	2 °C
TOL	2 °C	2 °C
Pdh Tj = +2°C	4.42 kW	4.39 kW
COP Tj = +2°C	3.49	2.21
Cdh Tj = +2 °C	1.000	1.000
Pdh Tj = +7°C	2.57 kW	2.75 kW
COP Tj = +7°C	5.53	3.54
Cdh Tj = +7 °C	1.000	1.000
Pdh Tj = 12°C	2.76 kW	2.61 kW
COP Tj = 12°C	6.45	4.89
Cdh Tj = +12 °C	0.990	0.990

This information was generated by the HP KEYMARK database on 28 Sep 2022

Pdh Tj = Tbiv	4.42 kW	4.39 kW
COP Tj = Tbiv	3.49	2.21
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	4.42 kW	4.39 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	3.49	2.21
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	1.000	1.000
WTOL	60 °C	60 °C
Poff	12 W	12 W
PTO	6 W	6 W
PSB	12 W	12 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	n/a	n/a
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Qhe	1033 kWh	1477 kWh

## Average Climate

<b>EN 12102-1</b>		
	<b>Low temperature</b>	<b>Medium temperature</b>
Sound power level indoor	38 dB(A)	38 dB(A)
Sound power level outdoor	63 dB(A)	63 dB(A)

<b>EN 14825</b>
-----------------

This information was generated by the HP KEYMARK database on 28 Sep 2022

	<b>Low temperature</b>	<b>Medium temperature</b>
$\eta_s$	182 %	134 %
Prated	3.67 kW	3.37 kW
SCOP	4.63	3.41
Tbiv	-10 °C	-10 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	4.20 kW	4.50 kW
COP Tj = -7°C	3.08	2.19
Cdh Tj = -7 °C	1.000	1.000
Pdh Tj = +2°C	2.66 kW	2.76 kW
COP Tj = +2°C	4.51	3.35
Cdh Tj = +2 °C	0.990	0.990
Pdh Tj = +7°C	2.72 kW	2.46 kW
COP Tj = +7°C	6.19	4.45
Cdh Tj = +7 °C	0.990	0.990
Pdh Tj = 12°C	3.01 kW	2.65 kW
COP Tj = 12°C	6.46	5.38
Cdh Tj = +12 °C	0.990	0.990
Pdh Tj = Tbiv	3.67 kW	3.37 kW
COP Tj = Tbiv	2.54	1.60
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	3.67 kW	3.37 kW



This information was generated by the HP KEYMARK database on 28 Sep 2022

COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.54	1.60
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	1.000	1.000
WTOL	60 °C	60 °C
Poff	12 W	12 W
PTO	6 W	6 W
PSB	12 W	12 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	n/a	n/a
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Qhe	1635 kWh	2042 kWh